

Design and implementation of Fuzzy-PID Controller with Derivative Filter for AGC of two-area interconnected Hybrid Power System

Binod Kumar Sahu, Pradeep Kumar Mohanty



Abstract: The huge band variation in wind speed causes unpredictable swing in power generation and hence large divergence in system frequency leading to unpredictable situation for standalone applications. To overcome the above difficulties, WTG (wind turbine generator) is integrated with conventional thermal power system along with other distributed generation units such as FC (fuel cell), DEG (diesel engine generator), AE (aqua-electrolyser) and BESS (battery energy storage system) which form a hybrid power system. This paper concerns with automatic generation control (AGC) of an interconnected two area hybrid power system as mentioned above. Design and implementation of suitable controllers for AGC of above hybrid power system is a challenging job for operational and design engineers. Various control schemes proposed in this paper are conventional PID & PID controller with derivative filter (PIDF) and fuzzy-PID controller without (fuzzy-PID) and with derivative filter (fuzzy-PIDF) to achieve improved performance of AGC system in terms of frequency profile. The values of gain parameters of proposed controllers are designed using hybrid LUS-TLBO (Local Unimodal Sampling-Teaching Learning Based Optimization) algorithm. Superiority of fuzzy-PIDF controller over other proposed controllers are addressed. Robustness study of proposed fuzzy-PIDF controller is thoroughly demonstrated with change in system parameters and loading pattern. The work is further extended to analyze the transient phenomena of the AGC for a 3-area interconnected system having nonlinearities such as reheat turbine, governor dead band along with generation rate constraint for the thermal generating units.

Keywords: - Automatic Generation Control (AGC), Proportional-Integral-Derivative (PID), PID with derivative filter (PIDF), Local Unimodal Sampling (LUS), Teaching Learning Based Optimization (TLBO).

I. INTRODUCTION

With huge population and large industrial growth, the demand of electrical power is continuously growing in last few decades. Due to gradual reduction of fossil fuel and increase in cost of fuel, the desired demand of electrical power may not be compensated with traditional way power generation. Also the impact of global warming and harmful effect of emissions of carbon on surrounding due to thermal power generation using fossil fuel brings new ideas for clean and sustainable energy sources. In addition to that deregulation of electricity scenario worldwide develops new perspective for generation of low power which is known as

distributed generation (DG). DG resources are generally used in the present scenario to fulfil the energy demand in the crisis. In the last decades technologies of DG system have provided solution to deficit in electrical energy to customers which are eco-friendly providing reliable and better power quality over conventional power generating possibility. The important issue in DG system is cost effective in terms of low transmission losses and less capital investments [1, 2]. A distributed generation system (DGs) is related with small electric power generating resources kept nearby its customers. The generating resources consists of wind energy, solar energy, diesel generator, biomass, fuel cells, geothermal power, energy storage system etc. Off grid electricity can be produced by using isolated power generating sources such as solar photo voltaic panels, micro-hydro plants, wind turbine generators (WTG) or fuel-power combustion engine generator set. Also a hybrid generating system can be implemented by combining two or more generating sources as stated above. Further to meet the hike of load demand of isolated consumer system, augmentation of DGs may be achieved by interconnecting it with traditional generating resources.

Now a day's photo voltaic and wind energy are introduced as sources of renewable energy which are clean and predominantly available in nature. Also wind energy is emerging as competitive and leading renewable source due to gradual advancement in technology, low cost of components and hike in the cost of fossil fuels. Because of advanced research and development in semiconductor manufacturing technology, the capacity utilization of photo voltaic power generation is increasing rapidly in order to cope up the growing of electrical power demand. But energy conversion efficiency of photo voltaic generation is low and is costlier compared with wind power. However, unfortunately generation of both photo voltaic and wind power are highly changing in nature due to random variations in solar radiation and wind speed that leads to unreliable situation for standalone applications. Fuel cell (FC) also provides alternate resource of energy in the form of heat and electricity to its consumers. Taking the above view into account, photo voltaic generators and off shore wind turbine can be integrated with standby diesel engine generator (DEG), fuel cell (FC) and few energy storage devices like BESS (battery energy storage system), SMES (superconducting magnetic energy storage system), flywheel energy storage system (FESS), CAES (compressed air energy storage) which are generally considered to store the surplus amount of energy and supply during the peak load demand [3-5].

Manuscript published on 30 August 2019.

*Correspondence Author(s)

Binod Kumar Sahu, Department of Electrical Engineering, ITER, SOA University, Bhubaneswar, Odisha, India. binoditer@gmail.com.

* Pradeep Kumar Mohanty, Department of Electrical Engineering, ITER, SOA University, Bhubaneswar, Odisha, India. mohanty.cbpur@gmail.com.

© The Authors. Published by Blue Eyes Intelligence Engineering and Sciences Publication (BEIESP). This is an [open access](https://creativecommons.org/licenses/by-nc-nd/4.0/) article under the CC-BY-NC-ND license <http://creativecommons.org/licenses/by-nc-nd/4.0/>.

Design and implementation of Fuzzy-PID Controller with Derivative Filter for AGC of two-area interconnected Hybrid Power System

However, FESS is affected by low energy density and BESS suffers from the difficulties involved in low rate of discharge, reversal of power flow and maintenance. For low power (less than 100 kW) application of SMES is not viable and it requires constant running of liquid helium system. Further CAES suffers from low efficiency and unfavourable environmental impact. Another choice of storage is ultra-capacitor (UC) which is used to smoothen large and short time power solicitation of distributed generation system and meet the load demand on account of its fast response, flexible and modular structure [6, 7].

In fact isolated hybrid renewable energy system is often more complex unlike the system which is connected to grid. The variation in both velocity of wind and solar radiation results in unbalance between generated power and demanded load which causes alternation in system frequency and generated voltage from their base values. Such types of undue variation if permitted beyond certain tolerance limit may cause unpredicted system performance which in turn damages the connected equipment/devices. Therefore it is quite obvious to preserve the power balance in between generation and demand. Through governor action, system frequency is regulated called primary control and frequency can also be adjusted to its nominal value using load frequency control (LFC) known as secondary control [8]. The secondary control is considered to obtain specific frequency regulation and to reduce tie-line unplanned power flows between interconnected neighbouring areas. In case of normal running environment the frequency lies in a narrow band around the operating frequency value. But, during abnormal situation such as tripping of one or few large generating units, sudden hike in load demand or sudden loss of long tie-line between any two interconnected areas force to tackle the frequency control problem. Therefore, LFC issue need to be thoroughly studied to keep the system power balance, such that the frequency and tie-line power deviation remain within specified limits.

For satisfactory operation of hybrid system effective management, coordination and control action are required between the generating and energy storing elements. Previously, so many controllers are being presented to study the LFC problems for getting a suitable dynamic performance. The conventional controllers (constant gain) such as PID are generally employed due to their fastness, robustness and simplicity in operation and structure. Initially the gains were tuned basing upon past experience or approaching trial and error based method which were no longer remain appropriate in all the operating conditions.

The simplest and oldest technique for determining the conventional PID controller gains is given in [9]. However this technique consumes more time for tuning and does not ensure the satisfactory performance of the process. Ziegler-Nichols [10] and Cohen-Coon [11] techniques are very popular and have been generally used for tuning the gains of controller. However the disadvantage of these techniques are (i) in case of noisy measurement, the performance of process may degrade and (ii) it makes the system's response more oscillatory leading to increase in settling time due to too aggressive values of controller setting. Hence the controller gains obtained from classical methods need to be finely tuned using many recently developed soft computing techniques. Selection of proper controller and suitable optimization technique to optimally design the gain parameters in the field AGC have been

attracting the researchers. Preedapong et al. [12] used linear matrix inequalities (LMI) method for H_{∞} control design in order to achieve robustness against uncertainties. Olio et al. [13] discussed the theoretical approach and operational design of an advanced pluralistic LFC scheme. A new robust PID controller was designed for AGC of hydro-power system and presented in [14]. Kothari et al. [15] conferred discrete mode AGC for an interconnected reheat type thermal system employing a new area control error which is based on frequency deviation, deviation in tie-line power, time error and unplanned load variation. LFC for a realistic interconnected system within a restructuring competitive electricity market scenario is discussed in [16]. Bhongade et al. [17] illustrated the accomplishment of SMES (super conducting magnetic energy storage) unit of ANN based AGC of two area interconnected power system. SMES is employed to inject or absorb active power in the power system. Sudha and Santhi [18] proposed a type2 fuzzy logic based method for AGC of interconnected two area reheat type thermal power system with GRC. In [19] Mohanty et al. applied DE algorithm for optimally tuning the gain parameters of conventional I, PI and PID controllers for AGC of an interconnected two area multi-source power system. Sahu et al. [20] have employed hybrid DE-PSO algorithm for tuning the gain parameters of conventional and fuzzy based PID controller to solve the AGC issues in both two area and three area thermal system. Optimal design of fuzzy-PID controller using TLBO algorithm for AGC of a two area interconnected power system is discussed in [21]. Arya and Kumar [22] successfully presented fuzzy gain scheduling controllers optimized through Genetic Algorithm for both two-area non-reheat & reheat thermal power system and multi-source multi-area hydro thermal power system. Arya and Kumar [23] demonstrated performance study of BFOA based fuzzy-PI/fuzzy-PID controller of AGC for multi-area interconnected conventional/restructured electrical power system. Dominance of fractional-order fuzzy-PID (FOFPID) controller optimized through BFOA for AGC of interconnected power system is proved over fuzzy-PID and conventional PID controllers in [24].

In the present study a conventional power system along with an isolated DG system works within a local area and is no longer widely spread over vast geographical region. Further the unpredictability of irregular renewable resources with variation of generation increases the complexity of power system structure which leads to high fluctuation in frequency response and therefore the frequency stability issues becomes a challenging task for operational engineers. In [25] frequency control for a hybrid power system in an island is discussed. Small signal stability analysis for a hybrid energy storage system is presented by Lee and Wang [26]. PI controller based small signal stability analysis of hybrid DG system is discussed in [27]. Das et al. [28] considered GA based frequency controller for hybrid power system comprising of solar-thermal-diesel-wind energy system. In [29, 30] robust H_{∞} controller for LFC in hybrid system is analyzed. In this paper a two-area interconnected hybrid power system is considered to study the AGC issues.

Individual area of the power system model consists of a conventional reheat turbine type thermal generating unit along with distributed generating sources such as WTG, FC, AE, DEG and BESS. Since wind power variation is stochastic in nature, incorporation of DGs particularly power generation using wind turbines makes the power system more complicated thereby imposes new challenges in regards to power system control. The dynamic performance of conventional power plants differs from power system incorporated with wind power generation. Output power from wind power sources depends on geographical position, seasons and weather conditions. Due to change in weather, wind speed varies resulting deviation of generation of wind power from its forecast value which causes imbalance between generated power and load demand. In this study hybrid LUS-TLBO based conventional PID controller & PID controller with derivative filter (PIDF) and fuzzy PID controller & fuzzy PID controller with derivative filter (fuzzy-PIDF) are implemented to tackle the AGC issues in the proposed two area hybrid power system.

II. POWER SYSTEM UNDER STUDY

A two-area interconnected hybrid power system consisting of conventional reheat type thermal power generating unit along with various DGs is shown in Figure 1. Since AGC study mainly deals with small perturbations, linearized models of various generating units are taken into consideration to study the dynamic behaviour of the proposed hybrid power system. Transfer function model of different distributed generating units are presented as follows:

A. Wind Turbine Generator (WTG)

The output power generated by wind turbine generator mainly depends on the velocity of wind and the wind velocity continuously changes with respect to time. The output power (mechanical) of wind turbine (P_{WT}) is directly proportional to cube of the wind speed as expressed below:

$$P_{WT} = \frac{1}{2} \rho C_p A_R V_w^3 \quad (1)$$

Where ' ρ ' is air density of air in Kg/m³, ' C_p ' is the coefficient of power, ' A_R ' is swept area of blade measured in m². ' V_w ' is the wind speed in m/sec. The expression of ' C_p ' is given by:

$$C_p = (0.44 - 0.0167\beta) \sin \left[\frac{\pi(\lambda - 3)}{15 - 0.3\beta} \right] - 0.0184(\lambda - 3) \quad (2)$$

Where ' λ ' is the tip speed ratio and ' β ' is the pitch angle of the blade. Tip speed ratio ' λ ' is expressed as:

$$\lambda = \frac{R_B w_B}{V_w} \quad (3)$$

' R_B ' is the radius of the blades in m, ' w_B ' is blade speed in rad/sec.

The wind turbine generating system is extremely nonlinear in nature. The wind turbine mechanical output power varies when pitch controller is used to counteract the oscillations in grid frequency. According to wind speed, the pitch system adjusts the pitch angle suitably which in turn introduces nonlinearities. However for small perturbation the system

nonlinearity may be linearized with some approximation. The linearized transfer function of wind turbine generator is given by:

$$T_{WTG} = \frac{\Delta P_{WTG}}{\Delta P_{WP}} = \frac{K_{WTG}}{1 + sT_{WTG}} \quad (4)$$

Where K_{WTG} is the gain and T_{WTG} is the time constant of wind turbine generator.

B. Aqua-Electrolyser (AE)

A part of the generation from WTG is fed to aqua-electrolyser for generation of hydrogen. When electric current is passed through aqueous electrolyte using electrodes, water is decomposed into hydrogen and oxygen. Hydrogen from AE is used by fuel cell which generates electrical power. Transfer function of AE is given by:

$$T_{AE} = \frac{\Delta P_{AE}}{u} = \frac{K_{AE}}{1 + sT_{AE}} \quad (5)$$

Where K_{AE} is the gain and T_{AE} is the time constant of aqua-electrolyser.

C. Fuel Cell (FC)

A fuel cell is primarily an electrochemical device that transforms chemical energy of hydrogen (fuel) into equivalent electrical energy by mixing air with gaseous hydrogen in the absence of combustion. A single fuel cell develops a very small voltage and to create sufficient voltage, fuel cells are arranged in series and parallel configurations which forms a fuel-cell stack. Various advantages of fuel cell generation in hybrid distributed power generating system are: high efficiency, low pollution, reusability of exhaust heat, diversity of fuels, and on-site installation. FC generating system is nonlinear possessing higher order. However for low frequency analysis, the system can be linearized to a first order system with transfer function expressed by:

$$T_{FC} = \frac{\Delta P_{FC}}{u} = \frac{K_{FC}}{1 + sT_{FC}} \quad (6)$$

Where K_{FC} is the gain and T_{FC} is the time constant of fuel cell.

D. Diesel Engine Generator (DEG)

Diesel engine acts as prime mover for the synchronous generator which generates electrical power. Due to uncertainty of wind power, imbalance between generated power and load demand occurs in a hybrid generating system. Since diesel engine generator has fast dynamic response and is capable of quickly rejecting the disturbance if any, it is the ultimate choice to maintain the balance between generated power and power demand. Due to presence of nonlinearity caused by the time delay in between injection and production of mechanical torque it is considered as nonlinear system. However with some approximation, the nonlinear DEG system can be linearized whose transfer function is expressed as:

$$T_{DEG} = \frac{\Delta P_{DEG}}{u} = \frac{K_{DEG}}{1 + sT_{DEG}} \quad (7)$$

Where K_{DEG} is the gain and T_{DEG} is the time constant of diesel engine generator.

E. Battery Energy Storage System (BESS)

The variation of wind energy originates severe problems for suitable operation of power system. The possible solution is to use the energy storage devices such as BESS. BESS provides supplemental damping for power system swing which improves both dynamic and transient stability of the power system. BESS possesses characteristics of fast access time as well as large energy density. Therefore, BESS is effectual to store huge quantity of wind energy during peak generation from WTG.

$$T_{BESS} = \frac{\Delta P_{BESS}}{u} = \frac{K_{BESS}}{1 + sT_{BESS}} \quad (8)$$

Where K_{BESS} and T_{BESS} are the gain and time constant of BESS respectively.

In this study various controllers such as conventional PID without and with derivative filter & fuzzy-PID without and with derivative filter (fuzzy-PIDF) are employed to analyze the dynamic performance of proposed hybrid power system. Power frequency balancing is achieved by the help of control signals ' u_1 ' & ' u_2 ' fed from the proposed design controller. In [29-30], the detailed mathematical model of various modules employed in hybrid DG power system are narrated and also data of various elements related with DG system under the study are mentioned. The equation given below describes the power balance in the system:

$$\Delta P_e = \Delta P_{DGS} + \Delta P_r - \Delta P_L \quad (9)$$

' ΔP_{DGS} ' represents power output from DG system, ' ΔP_r ' ($= \Delta P_{th}$) represents the power output from reheat type thermal power system and ' ΔP_L ' is change in load demand and ' ΔP_e ' represents the error produced in power supply. The total generated output power from hybrid DG system is given by

$$\Delta P_{DGS} = \Delta P_{WTG} - \Delta P_{AE} + \Delta P_{FC} + \Delta P_{DEG} \mp \Delta P_{BESS} \quad (10)$$

Where, ' ΔP_{WTG} ', ' ΔP_{AE} ', ' ΔP_{FC} ', ' ΔP_{DEG} ' and ' ΔP_{BESS} ' represent the change in electrical power generated by WTG, AE, FC, DEG and BESS respectively. The influence of variation of wind power on the system frequency response is a major factor to analyze deeply the LFC issue in proposed hybrid system.

The transfer function ' T_{st} ' of the system is the ratio of frequency variation to variation in per unit value of error in power and is expressed as:

$$T_{st} = \frac{\Delta f}{\Delta P_e} = \frac{K_p}{1 + sT_p} \quad (11)$$

Where, ' T_p ' & ' K_p ' are equivalent time and gain constant of plant respectively. All the parameters of the proposed hybrid power system are given in Appendix.

III. CONTROL STRATEGY & IMPLEMENTATION OF HYBRID LUS-TLBO ALGORITHM

AGC issue in two area hybrid electrical power system shown in Figure 1 is studied by using various controllers like PID, PIDF, fuzzy PID and fuzzy PIDF. Structures of these controllers are shown in Figures 2-5. For the fuzzy logic based controllers structure of membership function is shown in Figure 6 and the rule base is depicted in Table 1. Triangular membership functions are employed for both the inputs and the output due to their simplicity and takes less computational time [31].

Any fuzzy logic system involves the following steps as depicted in Figure 7

- Fuzzyfication: - It is the process of conversion of crisp input into a linguistic variable with the help of membership functions.
- Interface engine: - It transforms the fuzzy input to fuzzy output by the help of if-then type fuzzy rules.
- Defuzzification: - It is the process of conversion of fuzzy output into crisp. There are many defuzzification processes; one of the most common methods is center of gravity technique.

Optimal gains of all these controllers are obtained by employing hybrid LUS-TLBO algorithm. A step load change of 0.01 pu for ΔP_L & ΔP_{WTG} is put in area-1 to study dynamic behavior of proposed hybrid power system. In this optimization process Integral Time Absolute Error (ITAE) is selected as objective function whose expression is given in equation (12). Controller gains are optimally designed by using hybrid LUS-TLBO algorithm by minimizing the fitness function. Controller gains are taken in the range [0.01-3.0] and range of derivative filter coefficient ' N ' is taken [300-500]. Population dimension and maximum number of iterations are both taken as 100. Optimized value of various controllers' gains are given in Table 2.

$$ITAE = \int_{t=0}^{t_{sim}} (|\Delta f_1| + |\Delta f_2| + |\Delta P_{tie}|) . t dt \quad (11)$$

Where Δf_1 , Δf_2 & ΔP_{tie} represent the frequency deviations in area-1, area-2 & tie line power deviation respectively. ' t_{sim} ' indicates the simulation time.

PID controller output in time domain and its transfer function are given by:

$$u(t) = K_p e(t) + K_i \int_0^t e(t) dt + K_d \frac{de(t)}{dt} \quad (13)$$

$$TF = \frac{U(s)}{E(s)} = K_p + \frac{K_i}{s} + K_d s \quad (14)$$




Figure 1 Proposed two area interconnected hybrid power system.




Figure 2 Schematic diagram of a process with PID controller.

Design and implementation of Fuzzy-PID Controller with Derivative Filter for AGC of two-area interconnected Hybrid Power System

PIDF controller's transfer function is given by

$$TF_{PIDF} = K_p + \frac{K_i}{s} + K_d \times \frac{Ns}{N+s} \quad (15)$$




Figure 3 Structure of PID controller with derivative filter (PIDF).




Figure 4 Schematic block diagram of a fuzzy-PID controller.




Figure 5 Fuzzy PID controller with derivative filter (fuzzy-PIDF).




Figure 6 Membership function for input and output.

Table 1 Rule base for fuzzy logic based controller.

ACE	ACE				
	NB	NS	Z	PS	PB
NB	NB	NB	NB	NS	Z
NS	NB	NB	NS	Z	PS
Z	NB	NS	Z	PS	PB
PS	NS	Z	PS	PB	PB
PB	Z	PS	PB	PB	PB




Figure 7 Block diagram representation of a fuzzy-logic system.

Overview of hybrid LUS-TLBO algorithm: - Local search algorithms are simple, more robust & gradient free and are applied widely in the area of hard computational problems. However main problem is that instead of the solution converges to global minima, there is a probability of convergence of the solution into a local minima. Also, as discussed previously global search techniques like PSO, DE, TLBO etc. are not preferred in case of a problem having less dimensions with few number of fitness evaluations or large dimensions with more fitness evaluations. So to get advantages of both local and global technique, LUS [32] algorithm is hybridized with TLBO [21] algorithm. Steps followed in LUS-TLBO algorithm are:

- i. **Initialization:** - Generate initial population ' x_k '.
- LUS Algorithm begins here*
- ii. Add ' x_k ' with another vector ' a_k ' which is generated randomly in the sampling range ' r ' to update the initial position.

$$x_{k,new} = x_k + a_k \quad (16)$$
- iii. Compare fitness value of ' x_k ' and ' $x_{k,new}$ '.
- iv. Accept ' $x_{k,new}$ ' if it is performing better else ' x_k ' and decrease the sampling range ' r '.
- LUS Optimization algorithm ends here.*
- TLBO Algorithm begins here*
- v. Consider ' $x_{k,new}$ ' as first population.
- vi. Compute ' M_{diff} ' which is the difference between mean results.

$$M_{diff} = rand \times (x_{best} - T_{ff} \times M_d) \quad (17)$$
- vii. Update ' $x_{k,new}$ ' by adding it with ' M_{diff} '.

$$x_{k,new1} = x_{k,new} + M_{diff} \quad (18)$$
- viii. Accept ' $x_{k,new1}$ ' if performs better, else ' $x_{k,new}$ '.
- ix. Permit the learner for interaction with rest of the learners to produce new solution ' $x_{k,new2}$ '.
- x. Lastly select ' $x_{k,new1}$ ' or ' $x_{k,new2}$ ' as per performance.

Repeat steps 'ii-x' until stopping criterion is obtained. Flowchart of the proposed hybrid LUS-TLBO, LUS and TLBO algorithms are shown in Figure 8.




Figure 8 Flowchart of hybrid LUS-TLBO algorithm.




Figure 9 Convergence characteristics of individual LUS & TLBO and hybrid LUS-TLBO algorithms.

IV. RESULT AND DISCUSSION

In this paper, AGC problem in a two area interconnected hybrid power system is addressed. Every area of the hybrid interconnected power system consists of a reheat type thermal generating unit and distributed generating units such as WTG, AE, FC, DEG and BESS. The proposed hybrid power system model as shown in Figure 1 is developed in MATLAB/Simulink environment and proposed hybrid LUS-TLBO program is written in .m file and taken to optimize the gains of proposed controllers whose values are depicted in Table 2. Using these controllers' gains dynamic performance of the proposed two area hybrid power system is measured by applying a quick step load change of 0.01 pu in area-1. Figures 10-12 show the frequency alteration in area-1 (Δf_1) & area-2 (Δf_2) and tie-line power alteration (ΔP_{tie}) after undergoing a step load perturbation of 0.01 pu in area-1 with different proposed controllers. Overshoot (O_{sh}), undershoot (U_{sh}) and settling time (T_s) (with 0.02% band for Δf_1 & Δf_2 and 0.005% band for ΔP_{tie}) of Δf_1 , Δf_2 and ΔP_{tie} with various controllers, optimized through hybrid LUS-TLBO algorithm are depicted in Table 3.




Figure 10 Frequency deviation in area-1.




Figure 11 Frequency deviation in area-2.




Figure 12 Tie-line power deviation.

Four performance indices such as U_{sh} , O_{sh} , T_s and the value of ITAE fitness function are chosen to compare the performance of various controllers. It is observed in Figures 10-12 and Table 3 that the suggested LUS-TLBO based fuzzy PIDF controller provides significant improvements in all the performance indices as against fuzzy-PID and conventional PID & PIDF controllers. Therefore, it can be concluded that the concept of adding derivative filter to fuzzy-PID controller improves the controller performance to a great extent. Percentage improvements in U_{sh} , O_{sh} and T_s with LUS-TLBO based fuzzy PIDF controller as compared to LUS-TLBO based fuzzy PID and conventional PIDF & PID controllers are depicted in Table 4. Percentage improvements in the form of bar plot is shown in Figure 13 for better comparison of controllers' performance.

From Table 4 and Figure 13, it is noticed that proposed LUS-TLBO based fuzzy PIDF controller improves U_{sh} of Δf_1 , Δf_2 & ΔP_{tie} by 65.61%, 71.01% & 66.88% respectively, O_{sh} of Δf_1 , Δf_2 & ΔP_{tie} by 57.12%, 65.29% & 62.44% and T_s of Δf_1 , Δf_2 & ΔP_{tie} by 36.33%, 67.97% and 73.24% respectively in comparison with LUS-TLBO based fuzzy PID controller. Similarly with the proposed fuzzy PIDF controller, improvement in U_{sh} of Δf_1 , Δf_2 & ΔP_{tie} are 78.82%, 90.29% and 87.99% respectively, in O_{sh} of Δf_1 , Δf_2 & ΔP_{tie} are 85.87%, 95.44% and 93.18% respectively, and in T_s of Δf_1 , Δf_2 & ΔP_{tie} are 57.93%, 83.1% and 83.66% respectively in comparison with LUS-TLBO based PIDF controller. Also with the proposed controller, improvement in U_{sh} of Δf_1 , Δf_2 & ΔP_{tie} are 83.55%, 93.33% and 90.85% respectively, in O_{sh} of Δf_1 , Δf_2 & ΔP_{tie} are 93.02%, 97.45% and 93.08% respectively and in T_s of Δf_1 , Δf_2 & ΔP_{tie} are 59.36%, 83.1% and 83.61% respectively in comparison with PID controller based on LUS-TLBO algorithm.

Table 2 Optimal controller gains of the two area power system.

Gains of LUS-TLBO based PID controller											
Thermal generating unit						Distributed generating units					
K_p	K_i	K_d				K_p	K_i	K_d			
2.9877	2.9667	0.4801				2.4558	0.7951	0.6744			
Gains of TLBO based PID controller											
1.8742	3.0000	0.5862				1.7653	2.7300	1.1564			
Gains of LUS based PID controller											
1.8863	2.9514	0.4718				1.6757	2.6792	0.0100			
Gains of PIDF controller											
Thermal generating unit						Distributed generating units					
K_p	K_i	K_d	N			K_p	K_i	K_d	N		
2.9906	2.9989	1.1425	301.00			1.0801	0.6492	2.9989	302.00		
Gains of fuzzy-PID controller											
Thermal generating unit						Distributed generating units					
K_{p1}	K_d	K_{p2}	K_i			K_{p1}	K_d	K_{p2}	K_i		
1.4075	0.5908	0.9393	1.7055			1.7879	0.0101	2.6163	1.2450		
Gains of fuzzy-PIDF controller											
Thermal generating unit						Distributed generating units					
K_{p1}	K_{d1}	K_{p2}	K_i	K_{d2}	N	K_{p1}	K_{d1}	K_{p2}	K_i	K_{d2}	N
2.9979	0.8046	1.4696	2.4505	0.1379	301.00	1.2018	0.1976	2.9902	1.5057	1.9106	316.2403

Table 3 U_{sh} , O_{sh} and T_s (0.02% band for Δf_1 & Δf_2 and 0.005% band for ΔP_{tie}) of Δf_1 , Δf_2 and ΔP_{tie} with different controllers.

Controller	Δf_1			Δf_2			ΔP_{tie}			ITAE
	U_{sh} in Hz (10^{-3})	O_{sh} in Hz (10^{-3})	T_s in sec	U_{sh} in Hz (10^{-3})	O_{sh} in Hz (10^{-3})	T_s in sec	U_{sh} in pu (10^{-3})	O_{sh} in pu (10^{-3})	T_s in sec	
LUS-TLBO fuzzy-PIDF	-2.0602	0.4541	1.91	-0.3515	0.0721	0.98	-0.1368	0.0296	1.18	0.0043
LUS-TLBO fuzzy-PID	-5.9906	1.0590	3.00	-1.2123	0.2077	3.06	-0.4130	0.0788	4.41	0.0121
LUS-TLBO PIDF	-9.7276	3.2142	4.54	-3.6202	1.58	5.8	-1.1392	0.4341	7.22	0.0692
LUS-TLBO PID	-12.5274	6.5090	4.70	-5.2733	2.8286	5.80	-1.4944	0.4277	7.20	0.0513
TLBO-PID	-13.0448	8.1029	5.47	-5.9968	4.7565	5.55	-1.7406	0.8149	6.67	0.0624
LUS-PID	-13.7321	9.3202	5.61	-6.4682	5.6245	5.35	-1.8446	0.9120	6.83	0.0647

Table 4 Percentage improvement in U_{sh} , O_{sh} and T_s with LUS-TLBO based PIDF controller.

	Δf_1			Δf_2			ΔP_{tie}			ITAE
	U_{sh}	O_{sh}	T_s	U_{sh}	O_{sh}	T_s	U_{sh}	O_{sh}	T_s	
In comparison with LUS-TLBO based fuzzy-PID controller	65.61	57.12	36.33	71.01	65.29	67.97	66.88	62.44	73.24	64.46
In comparison with LUS-TLBO based PIDF controller	78.82	85.87	57.93	90.29	95.44	83.10	87.99	93.18	83.66	93.79
In comparison with LUS-TLBO based PID controller	83.55	93.02	59.36	93.33	97.45	83.10	90.85	93.08	83.61	91.62




Figure 13 Percentage improvement in the form of bar plot.

Integral time absolute error (ITAE) also plays a main role in optimally designing the values of controller gains. Less is the ITAE value better is the system performance and vice versa. It is seen in Table 4 and Figure 13 that improvement in ITAE with proposed LUS-TLBO based fuzzy PIDF controller are 64.46%, 93.79% and 91.62% in comparison with LUS-TLBO based fuzzy-PID and conventional PIDF & PID controller respectively. Therefore it can be finally concluded that the proposed LUS-TLBO based fuzzy PIDF controller outperforms the other proposed controllers.

V. SENSITIVITY ANALYSIS

Sensitive/robustness analysis of the proposed LUS-TLBO based fuzzy PIDF controller is done in order to prove its efficacy under system parametric variation. With optimal controller gains as depicted in Table 2, robustness analysis is done by (i) randomly varying the loading pattern in both the areas of the power system and (ii) varying one at a time, parameters of the hybrid power system in the range of -50% to +50% in steps of 25% of their nominal values.

A. Sensitivity analysis by randomly varying the loading patterns

To prove the robustness of the suggested controller against variation in electrical power demand, both the area of the power system subjected to randomly varying loading pattern as shown in Figures 14 and 15 respectively. This study is done by taking the nominal system parameters as given in Appendix. Frequency deviation in area 1 & area 2 and tie-line power deviation due to randomly varying loading patterns in area 1 (Figure 14) and area 2 (Figure 15) are shown in Figures 16, 17 and 18 respectively. It is noted from Figures 16, 17 and 18 that both fuzzy-PIDF and fuzzy-PID controllers exhibit stable dynamic performance under randomly varying loading patterns in area-1 and area-2. However fuzzy-PIDF controller exhibits less undershoot/overshoot and settles quickly as against fuzzy PID controller. Therefore, finally it can be inferred that the proposed LUS-TLBO optimized fuzzy-PIDF controlled AGC system for the hybrid power system is robust against variation in loading conditions.




Figure 14 Random loading pattern in area-1.




Figure 15 Random loading pattern in area-2.




Figure 16 Frequency deviation in area-1 due to random fluctuation of power demand in area-1 and area-2.




Figure 17 Frequency deviation in area-2 due to random fluctuation of power demand in area-1 and area-2.




Figure 18 Tie-line power deviation due to random fluctuation of power demand in area-1 and area-2.

B. Sensitivity analysis by varying all the parameters of the proposed power system

In this study, all the system parameters are varied within -50% to 50% in steps of 25% to prove the robustness of the suggested LUS-TLBO based fuzzy PIDF controller against parametric variation. A step load change of 1% is taken in area 1 in this study and U_{sh} , O_{sh} & T_s of Δf_1 ,

Δf_2 & ΔP_{tie} are depicted in Table 5. Statistical study of Table 5 is carried out by taking maximum, minimum & mean value along with standard deviation which are mentioned in Table 6. In Table 6, it is clearly verified that every transient parameter such as U_{sh} , O_{sh} & T_s change within a narrow range. Percentage deviation of mean values of U_{sh} , O_{sh} & T_s from their nominal values are given in Table 7. It is seen from Table 7 that with system parametric variation the percentage deviation of mean values from nominal value lie in the range of -6.01 to 0.77 % only.

From above Tables, Figures and analysis it is concluded that overshoot, undershoot and settling time of Δf_1 , Δf_2 and ΔP_{tie} of the suggested two area hybrid power system with LUS-TLBO based fuzzy PIDF controller vary within acceptable range. Hence, it can be conferred that the proposed LUS-TLBO based fuzzy PIDF controller is robust against variation in loading pattern as well as parametric variation.

Table 5 Robustness analysis with parametric variation using the proposed LUS-TLBO optimized fuzzy-PIDF controller.

Parameters	% age deviation	Numerical values after deviation	U_{sh} $\times 10^{-3}$ of Δf_1 (in Hz)	O_{sh} $\times 10^{-3}$ of Δf_1 (in Hz)	T_s of Δf_1 (in sec)	U_{sh} $\times 10^{-3}$ of Δf_2 (in Hz)	O_{sh} $\times 10^{-3}$ of Δf_2 (in Hz)	T_s of Δf_2 (in sec)	U_{sh} $\times 10^{-3}$ of ΔP_{tie} (in pu)	O_{sh} $\times 10^{-3}$ of ΔP_{tie} (in pu)	T_s of ΔP_{tie} (in sec)
K_{WTG}	-50%	0.5	-2.1281	0.3029	1.77	-0.3796	0.0369	1.15	-0.1499	0.0152	1.44
	-25%	0.75	-2.0941	0.3766	1.84	-0.3571	0.0522	1.05	-0.1429	0.0215	1.30
	25%	1.25	-2.0313	0.5377	1.97	-0.3343	0.0953	0.90	-0.1306	0.0393	1.08
	50%	1.5	-2.0026	0.6229	2.02	-0.3170	0.1216	0.84	-0.1247	0.0502	2.53
T_{WTG}	-50%	0.75	-1.9506	0.5165	1.64	-0.3027	0.0663	0.79	-0.1179	0.0266	0.97
	-25%	1.125	-2.0231	0.4863	1.82	-0.3298	0.0713	0.90	-0.1295	0.0291	1.09
	25%	1.875	-2.0867	0.4272	1.96	-0.3513	0.0712	1.02	-0.1411	0.0295	1.25
	50%	2.25	-2.1045	0.4011	1.98	-0.3627	0.0695	1.06	-0.1446	0.0289	1.30
K_{AE}	-50%	0.001	-2.0846	0.4553	1.91	-0.3531	0.0721	0.98	-0.1381	0.0297	1.19
	-25%	0.0015	-2.0667	0.4535	1.91	-0.3532	0.0720	0.98	-0.1372	0.0297	1.18
	25%	0.0025	-2.0538	0.4520	1.91	-0.3498	0.0719	0.97	-0.1365	0.0297	1.18
	50%	0.003	-2.0475	0.4513	1.91	-0.3472	0.0720	0.97	-0.1362	0.0296	1.18
T_{AE}	-50%	0.25	-2.0422	0.4526	1.91	-0.3485	0.0719	0.97	-0.1362	0.0295	1.18
	-25%	0.375	-2.0534	0.4556	1.91	-0.3489	0.0719	0.97	-0.1365	0.0297	1.18
	25%	0.625	-2.0647	0.4544	1.91	-0.3528	0.0720	0.98	-0.1370	0.0297	1.18
	50%	0.75	-2.0669	0.4531	1.91	-0.3525	0.0720	0.98	-0.1372	0.0297	1.18
K_{FC}	-50%	0.005	-2.0685	0.4553	1.91	-0.3530	0.0724	0.98	-0.1374	0.0297	1.18
	-25%	0.0075	-2.0649	0.4538	1.91	-0.3527	0.0720	0.97	-0.1371	0.0297	1.18
	25%	0.0125	-2.0555	0.4519	1.91	-0.3513	0.0717	0.97	-0.1366	0.0296	1.18
	50%	0.015	-2.0509	0.4526	1.91	-0.3491	0.0720	0.97	-0.1363	0.0296	1.18
T_{FC}	-50%	2.0	-2.0426	0.4533	1.91	-0.3459	0.0721	0.97	-0.1359	0.0297	1.18
	-25%	3.0	-2.0542	0.4518	1.91	-0.3509	0.0717	0.97	-0.1365	0.0296	1.18
	25%	5.0	-2.0639	0.4533	1.91	-0.3522	0.0720	0.97	-0.1370	0.0297	1.18
	50%	6.0	-2.0664	0.4543	1.91	-0.3532	0.0721	0.98	-0.1372	0.0297	1.18
K_{BESS}	-50%	-0.00165	-2.0026	0.4495	1.89	-0.3394	0.0705	0.96	-0.1339	0.0292	1.18
	-25%	-0.002475	-2.0306	0.4501	1.90	-0.3464	0.0715	0.97	-0.1356	0.0292	1.18
	25%	-0.004125	-2.0772	0.4582	1.91	-0.3527	0.0727	0.97	-0.1370	0.0299	1.18
	50%	-0.00495	-2.1121	0.4594	1.91	-0.3484	0.0721	0.98	-0.1379	0.0298	1.18

Design and implementation of Fuzzy-PID Controller with Derivative Filter for AGC of two-area interconnected Hybrid Power System

T_{BESS}	-50%	0.050	-2.0895	0.4547	1.92	-0.3583	0.0712	0.99	-0.1403	0.0296	1.20
	-25%	0.075	-2.0610	0.4539	1.91	-0.3516	0.0721	0.98	-0.1372	0.0299	1.18
	25%	0.125	-2.0485	0.4512	1.90	-0.3477	0.0720	0.97	-0.1361	0.0295	1.18
	50%	0.15	-2.0406	0.4504	1.90	-0.3418	0.0711	0.97	-0.1351	0.0293	1.18
K_{DEG}	-50%	0.0017	-2.0663	0.4551	1.91	-0.3532	0.0724	0.98	-0.1372	0.0298	1.18
	-25%	0.0025	-2.0632	0.4531	1.91	-0.3520	0.0720	0.97	-0.1370	0.0297	1.18
	25%	0.0041	-2.0572	0.4541	1.91	-0.3521	0.0717	0.97	-0.1367	0.0296	1.18
	50%	0.0049	-2.0542	0.4519	1.91	-0.3509	0.0716	0.97	-0.1365	0.0296	1.18
T_{DEG}	-50%	1.0	-2.0493	0.4543	1.91	-0.3481	0.0721	0.97	-0.1363	0.0297	1.18
	-25%	1.5	-2.0564	0.4522	1.91	-0.3515	0.0717	0.97	-0.1366	0.0295	1.18
	25%	2.5	-2.0625	0.4530	1.91	-0.3517	0.0720	0.97	-0.1369	0.0297	1.18
	50%	3.0	-2.0641	0.4536	1.91	-0.3519	0.0719	0.97	-0.1371	0.0297	1.18
R_1	-50%	1.2	-2.0545	0.4358	1.90	-0.3395	0.0699	0.96	-0.1348	0.0297	1.19
	-25%	1.8	-2.0579	0.4448	1.84	-0.3482	0.0637	0.97	-0.1362	0.0264	1.18
	25%	3.0	-2.0616	0.4589	1.91	-0.3526	0.0725	0.98	-0.1373	0.0297	1.18
	50%	3.6	-2.0625	0.4618	1.92	-0.3547	0.0730	0.98	-0.1375	0.0297	1.18
K_P	-50%	60.0	-1.7083	0.4808	1.87	-0.3406	0.0763	1.01	-0.1335	0.0301	1.16
	-25%	90.0	-1.8880	0.4589	1.89	-0.3410	0.0732	0.97	-0.1333	0.0298	1.17
	25%	150.0	-2.3379	0.4599	1.87	-0.3734	0.0617	1.01	-0.1472	0.0253	1.22
	50%	180.0	-2.5637	0.4674	1.96	-0.3827	0.0679	1.03	-0.1541	0.0283	1.25
T_P	-50%	10.0	-3.0817	0.4807	1.93	-0.4320	0.0550	1.09	-0.1735	0.0234	1.32
	-25%	15.0	-2.4168	0.4603	1.95	-0.3776	0.0700	1.01	-0.1489	0.0292	1.23
	25%	25.0	-1.9222	0.4579	1.90	-0.3420	0.0729	0.97	-0.1341	0.0298	1.17
	50%	30.0	-1.8294	0.4635	1.88	-0.3393	0.0735	0.98	-0.1330	0.0299	1.16
T_t	-50%	0.15	-1.2822	0.3679	1.99	-0.2564	0.0756	0.94	-0.1035	0.0311	1.23
	-25%	0.225	-1.6337	0.4042	1.95	-0.2844	0.0740	0.95	-0.1168	0.0304	1.20
	25%	0.375	-2.4780	0.5314	1.88	-0.4178	0.0704	0.98	-0.1598	0.0291	1.17
	50%	0.45	-2.8799	0.6414	1.86	-0.4866	0.0697	0.98	-0.1847	0.0288	1.16
K_r	-50%	0.25	-3.9561	1.1632	2.37	-0.8133	0.1685	1.17	-0.2981	0.0616	3.26
	-25%	0.375	-2.7242	0.6600	2.16	-0.4961	0.0999	1.09	-0.1888	0.0402	1.25
	25%	0.626	-1.6514	0.3352	1.70	-0.2668	0.0559	0.83	-0.1067	0.0233	1.12
	50%	0.75	-1.3696	0.2567	1.45	-0.2146	0.0383	0.63	-0.0863	0.0161	1.03
T_r	-50%	5.0	-2.0496	0.4795	1.88	-0.3415	0.0733	0.93	-0.1337	0.0302	1.13
	-25%	7.5	-2.0562	0.4636	1.90	-0.3499	0.0726	0.96	-0.1358	0.0300	1.16
	25%	12.5	-2.0628	0.4453	1.91	-0.3518	0.0711	0.98	-0.1375	0.0293	1.19
	50%	15.0	-2.0645	0.4403	1.91	-0.3528	0.0703	0.99	-0.1379	0.0290	1.20
K_g	-50%	0.5	-1.7102	0.4270	1.96	-0.3281	0.0733	1.02	-0.1302	0.0302	1.23
	-25%	0.75	-1.8440	0.4485	1.93	-0.3342	0.0726	0.99	-0.1325	0.0299	1.19
	25%	1.25	-2.3379	0.4650	1.90	-0.3715	0.0704	0.98	-0.1448	0.0290	1.19
	50%	1.5	-2.6139	0.4776	1.90	-0.4013	0.0687	0.99	-0.1550	0.0283	1.20
T_g	-50%	0.04	-4.0142	1.0102	2.53	-0.8506	0.1438	1.27	-0.3113	0.0551	3.37
	-25%	0.06	-2.7358	0.6258	2.17	-0.5043	0.0950	1.12	-0.1918	0.0382	1.29
	25%	0.1	-1.6480	0.3467	1.63	-0.2649	0.0505	0.82	-0.1056	0.0213	1.10
	50%	0.12	-1.3662	0.2784	1.52	-0.2072	0.0496	0.59	-0.0851	0.0209	1.00

Table 6 Statistical analysis of Table 5.

Statistical parameters	Δf_1			Δf_2			ΔP_{tie}		
	U_{sh} (in Hz) (10^{-3})	O_{sh} (in Hz) (10^{-3})	T_s (in sec)	U_{sh} (in Hz) (10^{-3})	O_{sh} (in Hz) (10^{-3})	T_s (in sec)	U_{sh} (in pu) (10^{-3})	O_{sh} (in Hz) (10^{-3})	T_s (in sec)
Maximum value	-4.0142	1.1632	2.53	-0.8506	0.1685	1.27	-0.3113	0.0616	3.37
Minimum value	-1.2822	0.2567	1.45	-0.2072	0.0369	0.59	-0.0851	0.0152	0.97
Average value	-2.1217	0.4719	1.9083	-0.3634	0.0733	0.9725	-0.1418	0.0300	1.2615
Standard deviation	0.4325	0.1236	0.1390	0.0924	0.0181	0.0926	0.0325	0.0066	0.3891

Table 7 Robustness comparison with fuzzy-PIDF controller.

	Δf_1			Δf_2			ΔP_{tie}		
	U_{sh}	O_{sh}	T_s	U_{sh}	O_{sh}	T_s	U_{sh}	O_{sh}	T_s
	Mean value								
	-2.1217	0.4719	1.9083	-0.3634	0.0733	0.9725	-0.1418	0.0300	1.2615
	Nominal value								
Fuzzy-PIDF controller	-2.0602	0.4541	1.91	-0.3515	0.0721	0.98	-0.1368	0.0296	1.18
	Percentage Deviation of mean value with respect to nominal value								
	-2.99	-3.92	0.089	-3.39	-1.66	0.77	-3.66	-1.35	-6.91

VI. PERFORMANCE EVALUATION OF LUS-TLBO BASED CONTROLLERS FOR A THREE AREA MULTI-UNITS INTERCONNECTED SYSTEM CONSIDERING NONLINEARITIES

To prove the efficacy of the proposed hybrid algorithm and fuzzy-PIDF controller, the work is further extended to a three area multi-units interconnected system having a thermal unit with GDB (governor dead band) and GRC (generation rate

constraint) and DGs' in each area. All the parameters of the extended system are depicted in Appendix-II. Transfer function model of the three area system is shown in Figure 19 (a). Detailed block diagram representation of thermal unit is shown in Figure 19 (b) and that of DGs' is shown in Figure 19 (c). Step load change of 1 % (0.01 pu) is applied in area-1 and fuzzy PIDF, fuzzy PID, PIDF and PID controllers and participation factor (PF) of thermal and DG are optimally designed using hybrid LUS-TLBO algorithm.




Figure 19 (a) Transfer function model of three area system.




Figure 19 (b) Transfer function model of thermal unit.

Design and implementation of Fuzzy-PID Controller with Derivative Filter for AGC of two-area interconnected Hybrid Power System




Figure 19 (c) Transfer function model of DG units.




Figure 20 Frequency deviation in area 1.




Figure 21 Tie-line Power deviation in tie-line 1.

For clear representation of variation in frequency in area 1 and tie-line power in tie-line 1 are shown in Figure 20 and 21 respectively. From Figures 20-21 it is proved the hybrid LUS-TLBO algorithm tuned fuzzy-PIDF controller outperforms the other proposed controllers.

VII. CONCLUSION

In this study, AGC study in an interconnected two-area hybrid power system is addressed. Every area of the interconnected power system consists of a thermal generating unit and five distributed generating units such as WTG (wind turbine generator), AE (aqua-electrolyser), FC (fuel cell), BESS (battery energy storage system) and DEG (diesel engine generator). Conventional controller such as PID controller & PID controller with derivative filter (PIDF) and fuzzy logic based controller such as fuzzy PID and fuzzy PID with derivative filter (fuzzy PIDF) are adopted to increase the performance of AGC system. All the controllers gains are optimally designed using hybrid LUS-TLBO algorithm. Results obtained are compared by taking transient parameters such as, overshoot, undershoot and settling time of frequency

variation in both areas and tie line power deviation. Analysis of result clearly demonstrates the superiority of fuzzy PIDF controller over other proposed controllers. Robustness study is done by randomly varying the loading pattern simultaneously in both the areas and by changing power system parameters from -50% to 50% in steps of 25%. Finally it is also proved that the proposed fuzzy PIDF controller for AGC of the proposed hybrid power system is robust against randomly varying loading conditions and system's parametric variation. Further the work is extended to a three area multi units system consisting one thermal and distribution generation units.

Appendix-I

Data used for AGC of two area multi-unit hydro-thermal power system.

Symbol	Parameters	Values used in this work [27]
$T_{g1} = T_{g2}$	Governor time constant	0.08 sec
$T_{t1} = T_{t2}$	Turbine time constant	0.3 sec
$T_{r1} = T_{r2}$	Re-heat time constant	10.0 sec
$K_{r1} = K_{r2}$	Re-heat gain	0.5
$T_{p1} = T_{p2}$	Control area time constant	20 sec
$K_{p1} = K_{p2}$	Control area gain	120
$R_1 = R_2$	Regulation constant	2.4 Hz/MW
$B_1 = B_2$	Frequency bias constant	0.425 MW/Hz
T_{12}	Synchronization coefficient	0.0433
K_{WTG}	Wind turbine generator gain	1.0
T_{WTG}	Wind turbine generator time constant	1.5 sec
K_{AE}	Gain of aqua-electrolyser	0.002
T_{AE}	Time constant of aqua-electrolyser	0.5 sec
K_{FC}	Gain of fuel cell	0.01
T_{FC}	Time constant of fuel cell	4.0 sec
K_{DEG}	Gain of diesel engine generator	0.0033
T_{DEG}	Time constant of diesel engine generator	2.0 sec
K_{BEES}	Gain of battery energy storage system	-0.0033
T_{BEES}	Time constant of battery energy storage system	0.1 sec

Appendix II

Data used for thermal unit of the three area multi-units power system

Symbol	Parameters	Values used in this work
T_g	Governor time constant	0.08 sec
T_t	Turbine time constant	0.3 sec
T_r	Reheat time constant	0.5 sec
K_r	Reheat gain	10
GDB	Governor dead band	0.036 Hz
GRC	Generation rate constraint	3 %

REFERENCES

1. M. A. Laughton, G. W. Brundrett, P. L. Surman, R. H. Taylor, *Electrical engineer's reference book*. 16th edition 2003, pp. 1–32, 2003.
2. L. D. James, Gil Melese-d'Hospital, "Energy supply and demand: strategies and alternatives for energy management," *Energy Conversation Management*, vol. 20, No.4, 1980, pp. 223–232, 1980.
3. L. Wang, D. J. Lee, W. J. Lee, Z. Chen, "Analysis of a novel autonomous marine hybrid power generation/energy storage system with a high-voltage direct current link," *Journal of Power Sources*, vol. 185, 2008, pp. 1284–1292.
4. W. Li, W. Joos, "Comparison of energy storage system technologies and configurations in a Wind Farm," *IEEE Power Electronics Specialists Conference (PESC)*, 2007, pp. 1280–1285.
5. I. Ngamroo, "Robust frequency control of wind–diesel hybrid power system using superconducting magnetic energy storage," *International Journal of Emerging Electric Power System*, Vol. 10, No. 2, 2009, pp. 1–26.
6. M. Uzunoglu, M. S. Alam, "Dynamic modeling, design and simulation of a combined PEM fuel cell and ultra-capacitor system for stand-alone application," *IEEE Transaction on Energy Conversion*, Vol. 21, No.3, 2006, pp. 767–775.
7. M. Uzunoglu, M. S. Alam, M. "Modeling and analysis of an FC/UC hybrid vehicular power system using a novel wavelet based load sharing algorithm," *IEEE Transaction on Energy Conversion*, Vol. 23, No.1, 2008, pp. 263–272.
8. P. Kundur, *Power System Stability and Control*, McGraw-Hill, 1994.
9. G. Ellis, *Control systems design guide*, Academic Press, London, 1991.
10. J. G. Ziegler, N. B. Nichols, "Optimum Settings for Automatic Controller," *Transaction of ASME*, Vol. 64 1942, pp. 759–768.
11. G. H. Cohen, G. A. Coon, "Theoretical considerations of retarded control," *Transactions of ASME*, Vol. 75, 1953, pp. 827–834.
12. D. Rerkpreedapong, A. Hasanovic, A. Feliachi, "Robust Load Frequency Control Using Genetic Algorithms and Linear Matrix Inequalities," *IEEE Transactions on Power Systems*, Vol. 18, No.2, 2003, pp. 855–861.
13. G. D. Olio, M. Sforna, C. Bruno, M. Pozzi, "A pluralistic LFC scheme for online resolution of power congestions between market zones," *IEEE Transactions on Power Systems*, Vol. 20, No. (4), 2005, pp. 2070–2077.
14. A. Khodabakhshian, R. Hooshmand, "A new PID controller design for automatic generation control of hydropower system," *International Journal of Electrical Power and Energy Systems*, Vol. 32, No. 5, 2010, pp. 375–382.
15. M. L. Kothari, J. Nanda, D. P. Kothari, S. Das, "Discrete mode automatic generation control of two areas reheat thermal system with new area control error," *IEEE Transactions on Power Systems*, vol. 4, No. 2, 1989, pp. 730–738.
16. B. Tyagi, S. C. Srivastava, "A LQG Based Load Frequency Controller in a Competitive Electricity Environment," *International Journal of Emerging Electric Power Systems*, Vol. 2, No. 2, 2005, pp. 1–15.
17. S. Bhongade, H. O. Gupta, B. Tyagi, "Performance of SMES unit on Artificial Neural Network based Multi-area AGC scheme," *Journal of Power Electronics & Power Systems*, Vol. 1, No. 1, 2011.
18. K. R. Sudha, R. VijayaSanthi, "Robust decentralized load frequency control of interconnected power system with Generation Rate Constraint using Type-2 fuzzy approach," *International Journal of Electrical Power and Energy Systems*, Vol. 33, No. 3, 2011, pp. 699–707.
19. B. Mohanty, S. Panda, P. K. Hota, "Controller parameters tuning of differential evolution algorithm and its application to load frequency control of multi-source power system," *International Journal of Electrical Power and Energy Systems*, Vol. 54, 2014, pp. 77–85.
20. B. K. Sahu, S. Pati, S. Panda, "Hybrid differential evolution particle swarm optimisation optimised fuzzy proportional-integral-derivative controller for automatic generation control of interconnected power system," *IET Generation, Transmission & Distribution*, Vol. 8, No. 11, 2014, pp. 1789–1800.
21. B. K. Sahu, S. Pati, P. K. Mohanty, S. Panda, "Teaching–learning based optimization algorithm based fuzzy-PID controller for automatic generation control of multi-area power system," *Applied Soft Computing*, Vol. 27, 2015, pp. 240–249.
22. Y. Arya, N. Kumar, "Fuzzy gain scheduling controllers for AGC of two-area interconnected electrical power systems," *Electric Power Components Systems*, Vol. 44, No. 7, 2016, pp. 737–751.
23. Y. Arya, N. Kumar, "Design and analysis of BFOA-optimized fuzzy PI/PID controller for AGC of multi-area traditional/restructured electrical power systems," *Soft Computing*, DOI: 10.1007/s00500-016-2202-2, June 2016.
24. Y. Arya, N. Kumar, "BFOA-scaled fractional order fuzzy PID controller applied to AGC of multi-area multi-source electric power generating systems," *Swarm and Evolutionary Computation*, Vol. 32, 2017, pp. 202–218.
25. T. Senjyu, T. Nakaji, K. Uezato, T. Funabashi, "A hybrid power system using alternative energy facilities in isolated island," *IEEE Transaction on Energy Conversion*, Vol. 20, No. 2, 2005, pp. 406–414.
26. D. J. Lee, L. Wang, "Small-signal stability analysis of an autonomous hybrid renewable energy power generation/energy storage system part I: time-domain simulations," *IEEE Transaction on Energy Conversion*, Vol. 23, No. 1, 2008, pp. 311–320.
27. P. Ray, S. Mohanty, N. Kishor, "Proportional integral controller based small signal analysis of hybrid distributed generation system," *Energy Conversion and Management*, Vol. 52, 2011, pp. 1943–54.
28. D. C. Das, A. K. Roy, N. Sinha, "GA based frequency controller for solar-thermal-diesel-wind hybrid energy generation/energy storage system," *International Journal of Electrical Power and Energy Systems*, Vol. 43, 2012, pp. 262–279.
29. V. Singh, S. Mohanty, N. Kishor, P. Ray, "H-infinity robust load frequency control in hybrid distributed generation systems," *International Journal of Electrical Power and Energy Systems*, Vol. 46, 2013, pp. 294–2305.
30. S. K. Pandey, N. Kishor, S. R. Mohanty, "Frequency regulation in hybrid power system using iterative proportional–integral–derivative H_{∞} controller," *Electrical Power Component and Systems*, Vol. 42, 2014, pp 132–148.
31. K. R. Mudi, R. N. Pal, "A robust self-tuning scheme for PI-and PID type fuzzy controllers," *IEEE Transactions on fuzzy systems*, Vol. 7, No. 1, 1999, pp 2–16.
32. P. K. Mohanty, B. K. Sahu, S. Panda, "Tuning and Assessment of Proportional–Integral–Derivative Controller for an Automatic Voltage Regulator System Employing Local Unimodal Sampling Algorithm," *Electrical Power Component and Systems*, Vol. 42, No. 9, 2014, pp. 959–969.